





**Balance ventilation in a good economic way
Ashrae Meeting May 2014,
Robert Johansson, product area director AHU**

- **Everybody's right to clean indoor air**


**Balance Ventilation –
Health business!!**

Life

- 🌐 We eat 1 kg per day
- 🌐 We drink 3 kg per day
- 🌐 We breathe 30 kg of air per day, which is about 25,000 litres!





**90% of our time is spent indoors -
90% of the air we breathe is therefore indoor air**



Balance Ventilation Supply/Exhaust
With heatrecovery –
Ventilation of people and all over
the house!

Good balance ventilation with, cross flow heatrecovery

- 90%
- Split exhaust and Supply air, No smell!
- EC-fan technology
- Low SFP
- Dubble By-Pass dampers







Example School in Hamburg




Double By-Pass dampers






Full heat demand




Over-capacity exchanger

Nominal (designed) airflow
Dry efficiency (%)



Over-capacity - operating


Nominal (designed) airflow
Means pressure drop (Pa)*
Extract filter F5 "Half dirty"



* Stated pressure drop are designed pressure drop at nominal airflow and applies on all Topvex SC sizes.


**In this situation you will save
117Pa with lower pressure drop**

Over-capacity heat recovery efficiency




No heat demand

Nominal (designed) airflow
Dry efficiency (%)




No heat demand - operating

Nominal (designed) airflow
Pressure drop (Pa)
Extract filter F5 "Half dirty"




**In this situation you will save
235Pa with lower pressure drop**

No heat demand




Free/Night cooling

Start Fans on set airflow (%)
When outdoor temp. on set temp.
Cool down the building to set temp.



Cool recovering

Closing dampers when indoor temp is a set value below outdoor temp.
Nominal (designed) airflow
Dry efficiency (%)



Conclusions

In this case: School in Hamburg

Air handling unit, 2160m³/h, 300Pa external pressure

— Full heat demand: Totally SFP 2.00

— Partly heat-demand: Exhaust-fan -117Pa = Totally SFP 1,78

— No heat-demand: Exhaust-fan -235Pa, Supplyfan-100Pa = Totally SFP 1,45

Mean annual SFP with by-pass dampers:

$$(1350/8760*2,0)+(6250/8760*1,78)+(1160/8760*1,45) = 1,77$$

Energy saving:

$$\text{Total SFP } 2,0 - 1,77 = 0,23$$

$$0,23 \text{ kWh} * 0,6 \text{ m}^3/\text{s} * 24 \text{ h} * 365 \text{ days} = 1209 \text{ kWh/year}$$



Conclusions

Average SFP with by-pass dampers will be much lower than a unit without the by-pass function

- **Energy saving!**
- **Three times less changes of exhaust filters**
- **Very good control of the supply temperature**

**Use balanced Ventilation and do
it in a good economic way!!**

There exist a lot of solutions!!

Thanks for listing!!